

May 7, 2020

Richardson Engineering  
30 East Padonia Road, Suite 500  
Timonium, MD 21093  
Attn: Mr. Patrick Richardson, P.E.

RE: 11414 Greenspring Ave  
100-Year Stormwater Management Variance  
Jones Falls Watershed  
**Project I.D. M190116**  
**Tracking Number: 02-20-3211**

Dear Mr. Richardson;

This office has reviewed the information submitted and finds that a stormwater management variance can be granted for this project under Section 33-4-113 (a) (2) of Title 4 of the Baltimore County Code. Section 33-4-113 (a) (2) allows a stormwater management variance to be granted if there are exceptional circumstances such that strict adherence to the provisions of the design standards would result in unreasonable hardship or practical difficulty and not fulfill the intent of the regulations.

This project is for the construction of a single-family dwelling and driveway. Although this site lies within an inter-jurisdictional watershed, which would therefore require stormwater management for the 100-year design storm, ESD will be provided to the MEP and no significant increase in runoff is anticipated for the 100-year design storm.

Please contact Andrew Fish, P.E. at 410-887-3768 should you have any questions.

Very truly yours,

*/signed/*

Kritty Udhin, P.E., Manager  
Stormwater Management  
Department of Environmental Protection  
& Sustainability

KU:jcm

c: Andrew Fish, P.E.